

Thank you for inviting us to your Agents Forum the other week. I hope we covered all the points you wanted us to and I am sorry for having to dash off! I was impressed with the turn out, we have been to a few of these and none as well attended as yours.

We were asked some questions which were not covered by our presentation. Would you be happy to put the following information on your website for agents?

### **First time connection to the public sewer:**

This process is started by Section 101a of the Water Industry Act, this is an application for first time sewerage connection. In order for an application to be valid a minimum of two properties need to be listed. Anglian Water advice that an application is made jointly with a neighbour or via a Parish Council. Please see our guide to First Time Sewerage. If you have any questions please contact [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk)

### **SuDS**

Anglian Water encourage developers to liaise with us in regards to SuDS adoption as soon as possible by submitting an expression of interest form available on our website.

<https://www.anglianwater.co.uk/developers/suds.aspx>

### **Sewers for Adoption 8**

This document contains guidance for the design and construction of sewers that will be adopted by water and sewerage companies, including Anglian Water. For the first time Sewers for Adoption includes SuDS.

Sewers for Adoption 8 (pre implementation version) and a document explaining the changes that have been made to Sewers for Adoption in relation to surface water sewers are available on the Water UK website. Whilst Sewers for Adoption 8 is not yet implemented Anglian Water is already working in-line with the principles.

<https://www.water.org.uk/policy/improving-resilience/sustainable-drainage-systems>

for general SuDS enquires please email [SuDS@anglianwater.co.uk](mailto:SuDS@anglianwater.co.uk)

Anglian Water will take part in multi agency group meetings to assist developers and the LPA if they are having issues or there are specific drainage concerns. Please contact [planningliaison@anglianwater.co.uk](mailto:planningliaison@anglianwater.co.uk) or [hwilson4@anglianwater.co.uk](mailto:hwilson4@anglianwater.co.uk) in these instances.

Any questions or if I have missed something out please let me know. I look forward to working with you soon.

Thank you

Kind regards  
Hannah Wilson  
Pre-Development Planning Manager

**Pre-Development Team**

Development Services

**Anglian Water Services Limited**

Thorpe Wood House, Thorpe Wood,  
Peterborough, Cambridgeshire, PE3 6WT  
Telephone: 0345 606 6087 option 1  
[www.anglianwater.co.uk](http://www.anglianwater.co.uk)